



FOUNDATION/LOWER LEVEL PLAN

SCALE: 1/4" = 1'-0"

1
S11



NOTE:
 4" W/ 2" TYPICAL
 16" FOOTINGS TYPICAL
 4" REBAR FOUNDATION DESIGN
 PER SITE SPECIFIC CONDITIONS

CRAWL SPACE NOTES:
 EACH SEPARATE CRAWL SPACE AREA TO HAVE 6 MIL VAPOR BARRIER OVER 6" CRUSHED GRAVEL. SEAM OVER LAP SHALL BE 6" MIN. & BE SEALED/TAPED. EDGES ARE TO EXTEND 6" MIN. UP STEEP WALL & BE SEALED/TAPED.
 EQUIPMENT INSTALLED AT GRADE LEVEL SHALL BE SUPPORTED ON A LEVEL CONCRETE SLAB AS INDICATED ON THE DRAWINGS AND EXTENDING A MIN. 3" ABOVE ADJOINING GRADE.
 AN APPROVED FUEL SHUTOFF VALVE SHALL BE INSTALLED IN THE FUEL SUPPLY PIPING SERVING EACH PIECE OF FUEL BURNING EQUIPMENT AT AN ACCESSIBLE LOCATION AHEAD OF THE UNION OR APPLIANCE CONNECTION WITHIN 36" OF THE EQUIPMENT.
 FURNACE TO BE LOCATED WITHIN 20" OF THE CRAWL SPACE OPENING (RE: PLAN). AN APPROVED INDEPENDENT MEANS OF DISCONNECT FOR THE ELECTRICAL SUPPLY TO EACH PIECE OF EQUIPMENT (SUS BOX).
 A PERMANENT SWITCH CONTROLLED LIGHT SHALL BE INSTALLED FOR MAINT. OF EQUIPMENT TO BE READILY ACCESSIBLE.
 A 120 VOLT SERVICE RECEPTACLE SHALL BE INSTALLED WITHIN 25' OF AND ON THE SAME LEVEL AS THE EQUIPMENT FOR MAINTENANCE.
 A PERMANENT LADDER SHALL BE CONSTRUCTED AT THE CRAWL SPACE OPENING TO PROVIDE ACCESS TO THE CONCRETE PAD BENEATH AND BE PROPERLY SECURED.
ANCHOR BOLTS:
 ANCHOR BOLTS ARE TO EXTEND A MIN. OF 7" INTO CONCRETE AND BE LOCATED WITHIN 12", BUT NOT LESS THAN 7 BOLT DIAMETERS FROM THE ENDS OF EACH PLATE. SPACING SHALL BE AS INDICATED ON EACH DETAIL (SHEET S1.2).

DENOTES HOLD DOWN
 (SIMPSON STD14 OR HIT T2)
 W/ 3/8" DIA. X 12" ANCHOR BOLTS CAST IN
 CONCRETE (EPOXY OR EMBEDDED)

FOUNDATION/FLOOR ELEVATION:
 TOP OF FOUNDATION TO BE SET A MIN. OF 12"-18"
 ABOVE TOP BACK OF CURB.

ADDRESS TBD
Nistler Columbia Garden #3 - Butte, MT
 Updated: November 17, 2010 - CLIENT REVIEW SET



Owner:
 Nistler Homes
 Matt Nistler
 (406) 581-6998

Designer:
 Mark Meissner
 5810 Stagecoach Trail Rd.
 Manhattan, MT 59741
 (406) 570-9576

SHEET
S2.1